Jigsaw
RUBBER MATTING

PRODUCT TEST DOCUMENTATION

Gripguard Datasheet DIN51130

Supplied by Jigsaw Rubber Matting, a trading name of Jigsaw Industrial Ltd.

The original manufacturer or independent laboratory report follows in full. Its issuer, applicant, test results and original references have been retained. Jigsaw Rubber Matting is the retailer, not the testing body.

For product advice and sales enquiries, contact our team.

01260 272313 | info@rubber-matting.co.uk
www.rubber-matting.co.uk

TEST REPORT

No. : XMML140703275
Date : Jul 21, 2014
Page: 1 of 2

AM@? Cspmnc

K_pj` mpmsef Bpgtc* Djcai l cw* Jcgacqrcp* JC6 6SP* Sl gcb l gl ebmk

The following sample(s) was/ were submitted and identified on behalf of the client as:

Sample Name	:	ANTI SLIP SAFETY MAT
Manufacturer	:	**AM@? Cspmnc**
Test required	:	Selected test(s) as requested by applicant
Date of Receipt	:	Jul 14, 2014
Test Period	:	Jul 14, 2014 to Jul 18, 2014
Test result(s)	:	For further details, please refer to the following page(s)

******** To be continued********

TEST REPORT

Test Item:

Slip resistance (ramp test)

Test method:

DIN 51130: 2010 Testing of floor coverings - Determination of the anti-slip properties - Workrooms and fields of activities with slip danger, walking method - Ramp test

Test Result:

Test item(s)	Test result(s)	Classification
Ramp test	Mean critical angle of inclination: 24.5°	R11

Classification of oil-wet ramp test:

Classification	Angle (degrees)
R9	6≤X<10
R10	10≤X<19
R11	19≤X<27
R12	27≤X<35
R13	≥35

Note: The above test was carried out by an external laboratory assessed as competent.

Specimen photograph:



SGS authenticate the photo on original report only

********End of report********